

Amendment to Tender #0171-1220
Provision of Mechanical Services for the Urology Suite

- Only one water closet required and location change; along with required plumbing and preparation. See new drawing
- WC1 shall be floor mounted instead of wall mounted. Acceptable product is American standard Madera FloWise 381mm (15") Height elongated flushometer 4.8L toilet or approved alternate. Colour to be white and include the American standard #5901 110 heavy duty open front less cover with EverClean surface. Also the flushometer valve shall be Delta exposed TECK flush valves for Sloan/Zurn Stops. Model 81T201-30 or approved alternate. The Sloan/Zurn stop to be included.
- Only one L1 sink required and location change; along with required plumbing and preparation. See new drawing.
- Location change of two of L2 sinks; along with required plumbing and preparation. See new drawing.
- Location change of wash disposal system; along with required plumbing and preparation. See new drawing.