

**ADDENDUM #1**

**DR. CHARLES L. LEGROW  
HEALTH CENTER,  
HEAT EXCHANGERS AND PUMPS REPLACEMENT  
PORT AUX BASQUE, NL**

This addendum shall form an integral part of the contract specification to be read in conjunction therewith. This addendum shall take precedence over all forms of the aforementioned specification with which it may prove to be at variance or may be otherwise be qualified in writing by authorized personnel.

**PART 1 Drawings**

1. Reference drawing ME-3, detail 2.
  1. Typical vertical in-line pump assembly piping detail - all fittings shown around the pump, butterfly valve, stainless steel flex connections, suction guide, flow-trex valve shall all be new. Piping drops down to existing pumps shall be modified as required to tie in new pump and fittings.
2. Reference drawing ME-3.
  1. Shell and tube heat exchanger, AIC shall be an acceptable alternate as long as all the aspects of the specifications and scheduled performances are met.

END