

Tender #: 0171-1802
Mechanical Systems Upgrade
Addendum #1

1. Reference Drawing M1 Controls Section
 - a. Delete Notes 2 through 12.
2. Reference Drawing M3
 - a. Add the following to Drawing Notes 1 "This work shall start at the end of the heating season on June 4, 2018, coordinate exact date with owner."
3. Reference Drawing M6 detail 1/M6
 - a. Add Note "Contractor is responsible for to complete work as per manufacture approved procedure for cleaning and converting R-22 refrigerant and oil out of the system to allow it to accept R410 and not affect the warranty of the new chiller."
 - b. Add Note "Contractor is responsible for all cost to expedite the process to get chiller onsite and install by the April 30th, 2018."