



## **Addendum # 1**

### **TENDER #0171-1903 Construction of new Isolation Room at Western Memorial Regional Hospital**

1. This Addendum shall form an integral part of the specification to be read in conjunction therewith. This Addendum shall take precedence over all forms of the specification with which it may prove to be at variance or may otherwise be qualified in writing by authorized personnel.
2. The General Conditions and all documents issued with this specification shall apply to govern all phases of the work covered by this Addendum.
3. The purpose of this Addendum is to inform bidders of clarifications to the contract documents.

#### **To advise Contractors of the following changes:**

1. Reference drawing M1, M3, M4  
As indicated in specification 01 11 00 section 1.2.6 “All low voltage wiring and connection to the existing building management system is by owner.”
2. Reference Drawing M3:
  1. Venturi valves and valve controls shall be supplied by Division 23
  2. Triatek Lab controls is an acceptable manufacturer for venturi valves.

#### **3. The Closing Date is amended to March 25, 2019.**

4. Amendment to Engineering Front End Document:  
Correction to heading name : In Specification Section 01 35 30 – Infection Control please note that where it indicates “Chemo Hood Installation Sir Thomas Roddick Hospital” it is meant to be “New Isolation Room Western Memorial Hospital “.

Contractors are advised to acknowledge receipt of this Addendum on the Tender Form when submitting a bid.

END