



**SPECIFICATIONS FOR  
TENDER #0171-1803  
SUPPLY AND INSTALLATION OF  
DIALYSIS PIPING MODIFICATION  
WESTERN HEALTH**

**Amendment 1 : Posted March 15<sup>th</sup>,2018**

**1. Reference Drawing M1, Plumbing Specification:**

Revise .6 Corrosion resistant piping, section .1 to read "All drainage and vent piping above ground including traps, waste and branch vents to be IPEX **Enfield System** drainage pipe or approved equal. The system to include all straight lengths, fittings and trap, couplings and hanger support as well as adaptors to connect to tail piece of sink"

- 2.** We have a contradictory statements in the tender documents. In the scope of the work to be completed it says owner is responsible for infectious control. But on the drawings it says that the contractor is responsible for infectious control. The scope of work section is amended to: "The contractor will be responsible for ensuring proper infection control procedures and practices are followed when conducting any work."

**CLOSING DATE: 20<sup>th</sup> of March, 2018**

**CLOSING TIME: 2:00 PM (Newfoundland Time)**

—