



**SPECIFICATIONS FOR**

**TENDER # 0171-1805  
Amendment #2**

**Repair/Modification  
to Two (2) Trane Cooling Towers  
Model BAC VLT550A S/N 72-3034/5CA**

**The following amendments are posted Feb 9<sup>nd</sup> 2018:**

**1. The closing Date is amended as follows:**

**CLOSING DATE: February 13<sup>th</sup> , 2018**

**CLOSING TIME: 2:00 PM (Newfoundland Time)**

**2. In section 2.0 under the scope of work section Line 15.  
Where it states that**

**“ Remove and dispose of the existing damper control system and supply and install four 10HP/575V Danfoss VFD drives complete with bypass, each VFD drive will control two 10 HP motors. “ The is amended to add: “Vendors can propose 8 VFD’s as an acceptable alternative.”**